



Certificate of Compliance

Certificate: 70113766

Master Contract: 181564

Project: 70113766

Date Issued: 2017-02-24

Issued to: **Delta Electronics (Thailand) Public Co., Ltd.**
909 Soi 9 Moo 4 Pattana 1 Rd
Bangpoo Industrial Estate E.P.Z.
Tambol Phraksa
Amphur Muang, Samut Prakan 10280
THAILAND

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Thian (Peter) Lim*
Thian (Peter) Lim

PRODUCTS

CLASS - 531103 - POWER SUPPLIES-Component Type

DIN Rail Power Supply, component type, Model DRM-24V960W1PX(y) (where X can be any alphanumeric except Y and Z or blank, (y) can be any alphanumeric or blank); permanently connected, intended for use in a controlled environment, rated as follows:

Model	Input			Output		
	Volts (V ac)	Amps (A)	Freq (Hz)	Volts (V dc)	Amps (A)	Power (W)
DRM-24V960W1PX(y)	100-240	12	50-60	24	40	960

Notes:

1. The wiring terminals are intended for Field wiring.



Certificate: 70113766

Project: 70113766

Master Contract: 181564

Date Issued: 2017-02-24

2. The above power supply has been evaluated in an ambient of 60°C @ 100% power, 70°C @ 75% power for vertical mounting, 40°C @ 100% power, 70°C @ 50% power for horizontal mounting.
3. The above power supply is certified only as a component for use in other equipment, where the suitability of the combination is to be determined in the end product.
4. The above power supply is designed for non-operator accessible area and it shall not to be used with a disconnecting connector (or attachment plug).

APPLICABLE REQUIREMENTS

CSA C22.2 No. 107.1-01 (R2011)

- General Use Power Supplies