

Ref. Certif. No.

DK-120092-UL

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME **CB TEST CERTIFICATE** Built-in LED Controlgear Product DELTA ELECTRONICS INC **3 TUNGYUAN ROAD** Name and address of the applicant CHUNGLI INDUSTRIAL ZONE TAOYUAN CITY 32063 TAIWAN DELTA ELECTRONICS INC Name and address of the manufacturer **3 TUNGYUAN ROAD** CHUNGLI INDUSTRIAL ZONE TAOYUAN CITY 32063 TAIWAN DELTA ELECTRONICS (WUHU) LTD Name and address of the factory NO. 138 JIUHUA NORTH ROAD LONGSHAN STREET ECONOMIC-TECHNICAL DEVELOPMENT AREA WUHU CITY, ANHUI Note: When more than one factory, please report on page 2 **PROVINCE**, 241008 CHINA Additional Information on page 2 EUCI-040105GLBXX: Input: 220-240 V~ 50/60 Hz 0.23 A λ:0.95 Ratings and principal characteristics Output: 20-77 V === 200-1050 mA 40 W max. ta= -40...+55°C, tc= +90°C Additional Information on page 2 Trademark (if any) Customer's Testing Facility (CTF) Stage used EUCI-040105GLBXX, EUCI-022105GLBXX Model / Type Ref. Additional Information on page 2 Additionally evaluated to: EN 61347-2-13:2014, EN 61347-2-Additional information (if necessary may also be 13:2014/AMD1:2017, EN 61347-1:2015 reported on page 2) National Differences specified in the CB Test Report. Additional Information on page 2 A sample of the product was tested and found IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016, IEC 61347-1:2015 to be in conformity with As shown in the Test Report Ref. No. which forms 4790120407.1 issued on 2021-10-28 part of this Certificate This CB Test Certificate is issued by the National Certification Body □ UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA 図 UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK □ UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA For full legal entity names see www.ul.com/ncbnames Date: 2021-10-28 Signature: Jan-Erik Storgaard



Ref. Certif. No.

DK-120092-UL

## Additional Model Detail(s):

EUCI-040105GLBXX, EUCI-022105GLBXX, where X can be any alphanumeric character or blank

## **Additional Ratings:**

EUCI-022105GLBXX: Input: 220-240 V~ 50/60 Hz 0.12 A λ:0.95 Output: 8-48 V== 200-1050 mA 22 W max. ta= -40...+55°C, tc= +85°C

Class II, SELV

## Additional information (if necessary)



□ UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA ⊠ UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK □ UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN □ UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2021-10-28

Signature: Jan-Erik Storgaard

lan out Superm