



产品认证证书

证书编号: CQC22001333779

发证日期: 2022年03月07日

有效期至: 长期有效

委托人名称 台达电子工业股份有限公司
及注册地址 台湾省 桃园县龟山乡山顶村兴邦路 31 之 1 号

制造商名称 台达电子工业股份有限公司
及注册地址 台湾省 桃园县龟山乡山顶村兴邦路 31 之 1 号

生产企业名称 台达电子(泰国)股份有限公司
及生产地址 泰国 北榄府 直辖县 拍卡沙区 第 4 村 909 号

产品名称和系列、规格、型号 开关电源
IMA-S2000-24-YVxxx & IMA-C2000-24-YVxxx [x = 0-9/空/A-Z, 表示不同的客户, 不影响产品的安全和电磁兼容性;] 输入: 100-127Vac/200-240Vac; 17A-15A Max/12A-9.8A Max; 50/60Hz; 120-300Vdc/12A-7.8A Max 直流输出: 5Vdc/2A max; 24Vdc/60.41A Max (@ 100-127Vac); 24Vdc; 83.4A Max (@ 200-240Vac); 24Vdc/41.7A Max (@ 120-240Vdc); 24Vdc/83.4A Max (@ 280-300Vdc); 最大输出功率 2010W max. 不配带电线组件销售, 仅适用于海拔 5000 米及以下

产品标准和技术要求 GB 17625.1-2012;GB 4943.1-2011;GB/T 9254-2008

认证模式 产品型式试验+获证后监督

上述产品符合 CQC12-045670-2015 认证规则的要求, 特发此证。

本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



签发: 谢肇煦



中国质量认证中心





CERTIFICATE OF PRODUCT CERTIFICATION

CERTIFICATE NO.: CQC22001333779

Valid from: Mar.07,2022

Valid until:long-term

NAME AND REGISTERED ADDRESS OF THE APPLICANT	Delta Electronics, Inc. 31-1, Shien Pan Road, Shanding Village, Guishanshan, Taoyuan County 33370, Taiwan
NAME AND REGISTERED ADDRESS OF THE MANUFACTURER	Delta Electronics, Inc. 31-1, Shien Pan Road, Shanding Village, Guishanshan, Taoyuan County 33370, Taiwan
NAME AND LOCATION OF THE FACTORY	Delta Electronics (Thailand) Public Co., Ltd. 909 Soi 9, Moo 4, Bangpoo Industrial Estate (E.P.Z), Pattana 1 Road, Tambol Phraksa, Amphur Muang, Samutprakarn, THAILAND
PRODUCT NAME, MODEL AND SPECIFICATION	Switching Power Supply IMA-S2000-24-YVxxx & IMA-C2000-24-YVxxx 【 x = 0-9, A-Z or blank, for different customers, which does not affect product safety and EMC 】 Input rating: 100-127Vac/200-240Vac; 17A-15A Max/12A-9.8A Max; 50/60Hz; 120-300Vdc/12A-7.8A Max Output rating: 5Vdc/2A max; 24Vdc/60.41A Max (@ 100-127Vac); 24Vdc; 83.4A Max (@ 200-240Vac); 24Vdc/41.7A Max (@ 120-240Vdc); 24Vdc/83.4A Max (@ 280-300Vdc); 最大输出功率 2010W max. Max output power 2010W max, Sale without cord set, Altitude up to 5000m
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS	GB 17625.1-2012;GB 4943.1-2011;GB/T 9254-2008
TYPE OF CERTIFICATION SCHEMES	Type Testing of Product + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-045670-2015.
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE

