



Certificate of Compliance

Certificate: 2571226

Master Contract: 181564

Project: 70202381

Date Issued: 2018-10-24

Issued to: **Delta Electronics (Thailand) Public Co., Ltd.**
909 Soi 9 Moo 4 Pattana 1 Rd
Bangpoo Industrial Estate E.P.Z.
Tambol Phraksa
Amphur Muang, Samut Prakan 10280
THAILAND
Attention: **Suttiruk Subniem**

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Edwin Chao*
Edwin Chao

PRODUCTS

CLASS - C531103 - POWER SUPPLIES-Component Type

DIN Rail Power Supply, component type, Models DRP024V120W3BX and DRP024V060W3BX (where X can be 0-1, a-z, A-Z or blank), permanently connected, intended for use in a controlled environment, rated as follows:

Model	Input			Output		
	Volts (V ac)	Amps (A)	Freq (Hz)	Volts (V dc)	Amps (A)	Power (W)
DRP024V120W3BX	3 x 400-500	0.5	50-60	24	5	120
DRP024V060W3BX	3 x 400-500	0.3	50-60	24	2.5	60



Certificate: 2571226
Project: 70202381

Master Contract: 181564
Date Issued: 2018-10-24

Notes:

1. The wiring terminals are intended for Field wiring.
2. The above power supply model DRP024V120W3BX has been evaluated in an ambient of
Vertical mounting: 50°C@100% load, 60°C@75% load, 70°C@50% load, 75°C@25% load.
Horizontal mounting: 40°C@100% load, 50°C@75% load, 60°C@50% load, 65°C@25% load.
3. The above power supply model DRP024V060W3BX has been evaluated in an ambient of
Vertical mounting: 50°C@100% load, 60°C@75% load, 70°C@50% load, 75°C@25% load.
Horizontal mounting: 45°C@100% load, 55°C@75% load, 70°C@50% load, 75°C@25% load.
4. The above power supplies are certified only as components for use in other equipment, where the suitability of the combination is to be determined in the end product.

APPLICABLE REQUIREMENTS

- CAN/CSA C22.2 No. 0-M91 - General Requirements - Canadian Electrical Code - Part II
- CSA C22.2 No. 0.4-04 - Bonding of Electrical Equipment
- CSA C22.2 No. 107.1-16 - Power Conversion Equipment