



Certificate of Compliance

Certificate: 2673200

Master Contract: 181564

Project: 80021312

Date Issued: 2019-10-22

Issued to: Delta Electronics (Thailand) Public Co., Ltd.
909 Soi 9 Moo 4 Pattana 1 Rd
Bangpoo Industrial Estate E.P.Z.
Tambol Phraksa
Amphur Muang, Samut Prakan 10280
THAILAND
Attention: Mr. Suttiruk Subniem

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Edwin Chao*
Edwin Chao

PRODUCTS

CLASS 5311 03 – POWER SUPPLIES - Component Type

DIN Rail DC UPS Module, component type, Model DRU-24V40ABX (where X can be 0-1, a-z, A-Z or blank), permanently connected, intended for use in a controlled environment, rated as follows:

Normal Mode (Discharge/Buffer Mode): Input 24 V dc, 40 A Max; Output 24 V dc, 40 A Max

Charge Mode: 24 V dc, 2 A

Notes:

1. The wiring terminals are intended for Field wiring.
2. The above DC UPS Module has been evaluated in an ambient of 60°C@100% power.
3. The above DC UPS Module is certified only as a component for use in other equipment, where the suitability of the combination is to be determined in the end product.

APPLICABLE REQUIREMENTS

CSA C22.2 No. 107.1-16 - Power Conversion Equipment